

M/s. BHARAT KUMAR SAHOO**(CONSULTANT ELECTRICAL ENGINEER & CONTRACTOR)****(An ISO 9001:2008 Certified)**PAN - AQEPS9899P
TIN - 21241307669
Civil (L) - 16808

At./Po./Via.: Rengali Dam Site, Dist.: Angul (Odisha) - 759105

Email - bharatkumarsahoog9@gmail.com

EPF - 16036

S. Tax - AQEPS9899PSD002

Elect. (L) - 2158 (HT)

Ref No.....QRJ/BKS/2011.

Date.....01/04/2014.....

To,

The Managing Director, Odisha Knowledge Corporation Ltd., Bhubaneswar.

(Subject: Verification report of ICT lab)

Dear Sir,

We are a registered contractor **M/s. Bharat Kumar Sahoo**, an approved Electrical contractor of Government of Odisha, bearing Licence No. 2158(HT)(Copy of license is enclosed) for your kind perusal. After verification of the following items of the ICT lab **TARANG HIGH SCHOOL, UDISE Code -21040223601**, Block-Reamal, District-Deogarh, as per the minimum specification mentioned below, the report for the same is being attached.

Sr. No.	Item name	Minimum Specifications	Quantity
1	Earthing (as per IS specifications)	Copper plate earthing stations making earthing with copper earth plate 600 mm x 600 mm x 3 mm thick including funnel, charcoal / coke, salt, all earth work.	1
2	Switches and sockets (ISI Mark)	5 A- 240 V switches (Including Switch Board)	15+9=24
		5 in 1 5A and 15A Sockets	19+1=20
		15 A - 240 V socket with shutter	1
		Indicative Brands: - Anchor / Havells / crabtree /Wipro /Phillips / Legrand (Pls. tick) Switches and sockets is to be provided for all electronics/IT equipment including printer and Projection System to be placed at lab technician table.	Anchor and Havells
3	Wiring (ISI Mark)	PVC conduits including MS/GI boxes. All wires should be covered, insulated and properly clamped. Wiring for 5 and 15A power outlets with 4 square mm PVC insulated stranded copper conductor wires Earthing of 3rd pin with PVC insulated green color 2.5 square mm copper wire	Full Lab

With regards
Name & Signature with seal