Er. Pradeep Kumar Rath

Electrical Engineer-cum-Govt. Elect. Contractor.

Licence No.1154 (HT) & SCC No.4412,

TIN: 21921904233



RESIDENCE :

At. Nagarampalli Street, PARLAKHEMUNDI - 761 200, Dist. Gajapati, Odisha.

Cell: +91-94372 16762

Date :

1227	no. To,								
Ref	Mo.	3		Ç,	ā	÷	ş	į	į

The Managing Director, Odisha Knowledge Corporation Ltd, Bhubaneswar,

Subject:- Verification report of ICT Lab.

Dear Sir,

We are a registered Contractor Er. Pradeep Kumar RAth, an approved Electrical Contractor of Government of Odisha, bearing Licence No.1154 (HT) (Copy of licence is enclosed) for your kind perusal.

After verification of the following items of the ICT Lab at GOVT.(SSD)GIRLS.HIGH SCHOOL, UDISE CODE: 21200207201,KCPUR, GAJAPATI as per the minimum specification mentioned below, the report for the same is being attached.

Sr.No	Item Name	Minimum Specifications	Qty	Remarks	
1.	Earthing (as per IS	Copper plate earthing stations making earthing with copper earth plate		OK	
	SPECIFICATION)	600 MM x 3MM thick including funnel,charcoal/coke,salt,all earth work		OK.	
2.	Switches and Sockets (ISI mark)	5A-240 V Switches	15	OK	
		2in 1 5A and 15A Sockets	1.50	ОК	
		15A - 240 V Socket With Shutter	2	1	
		Indicative Brands:- Anchor/Haveels/Crabtree/Wipro/Philips/Legrands(Pls.tick)Switches and Sockets is to be provided for all electronics/IT equipment including printer and protection system to be placed at lab technician table.		Anchor	
3.	Wiring (IS Mark)	PVC conducts including MS/GI boxes.All wires should be covered, insulated and properly clamped. Wiring for 5 and 15 a power outlets with 4square mm PVC insulated stranded copper conducater wires Earthing of 3 rd pin with PVC insulated green color 2.5 square mm copper Wire.	Full lab	Yes	

With regards

Name & signature With seal

RATHA ELECTRICAL POWER CONSTRUCTIONS