## Er. Pradeep Kumar Rath

Electrical Engineer-cum-Govt. Elect. Contractor. Licence No.1154 (HT) & SCC No.4412, TIN: 21921904233



## RESIDENCE

At. Nagarampalli Street, PARLAKHEMUNDI - 761 200,

Dist. Gajapati, Odisha Cell : +91-94372 16762

Date: ....

Tel Tola		
West STA	904	

The Managing Director,
Odisha Knowledge Corporation Ltd,
Bhubaneswar,

Subject:- Verification report of ICT Lab.

Dear Sir,

We are a registered Contractor Er.Pradeep Kumar RAth, an approved Electrical Contractor of Government of Odisha, bearing Licence No.1154 (HT) (Copy of licence is enclosed) for your kind perusal.

After verification of the following items of the ICT Lab at u.GOVT.HIGH SCHOOL, UDISE CODE:-21200301401,goribandha, GAJAPATI as per the minimum specification mentioned below, the report for the same is being attached.

Sr.No	Item Name	Minimum Specifications	Qty	Remarks
IS	Earthing (as per IS	Copper plate earthing stations making earthing with copper earth plate		ОК
	SPECIFICATION)	600 MM x 3MM thick including funnel, charcoal/coke, salt, all earth work		
2. Switches and Sockets (ISI mark)	Switches and	5A-240 V Switches	15	OK
	Sockets (ISI mark)	2in 1 5A and 15A Sockets		ОК
	15A - 240 V Socket With Shutter	2	1	
	Indicative Brands:- Anchor/Haveels/Crabtree/Wipro/Philips/Legrands( Pls.tick)Switches and Sockets is to be provided for all electronics/IT equipment including printer and protection system to be placed at lab technician table.		Anchor	
3.	Wiring (IS Mark)	PVC conducts including MS/GI boxes.All wires should be covered, insulated and properly clamped. Wiring for 5 and 15 a power outlets with 4square mm PVC insulated stranded copper conducater wires Earthing of 3 <sup>rd</sup> pin with PVC insulated green color 2.5 square mm copper Wire.	Full lab	Yes

With regards

Name & signature With Seal

Er Pradeon Kumat Rath Ene Comisciora Sapenisor L NoATBA (HTT6 SCC No-4412 DARALAICHEMULD)

## RATHA ELECTRICAL POWER CONSTRUCTIONS