

# SYAG ELECTRICALS & CONSTRUCTION

*Deals in : Baial Electrical Products.*

We undertake : All types of Electrical Wiring, L.T. Works & Govt. Order Suppliers  
Main Road, Ganjam - 761026 (Odisha)

Ref. No.....

Date.....

The Managing Director,  
Odisha Knowledge Corporation Ltd.,  
Bhubaneswar.  
Subject: Verification report of ICT lab

Dear Sir,

We are a registered contractor PRADOSH KUMAR DAS, an approved Electrical contractor of Government of Odisha, bearing Licence No.1815 HT (Copy of license is enclosed) for your kind perusal.

After verification of the following items of the ICT lab at, GOVT U.G. HIGH SCHOOL, KUMARIPARI, <<21190210101>>, <<BEGUNAPADA>>, <<GANJAM>> as per the minimum specification mentioned below, the report for the same is being attached.

Sr. No.	Item name	Minimum Specifications	Quantity	Remark
1	Earthing (as per IS specifications)	Copper plate earthing stations making earthing with copper earth plate	1	iron make Earthing pipe used
		600 mm x 600 mm x 3 mm thick including funnel, charcoal/coko, salt, all earth work.		Yes
2	Switches and sockets (ISI Mark)	5 A- 240 V switches	15	Yes
		2 in 1 5A and 15A Sockets	15	Yes
		15 A - 240 V socket with shutter	2	Yes
		Indicative Brands: - Anchor / Havells / crabtree / Wipro / Phillips / Legrand (Pls. tick) Switches and sockets is to be provided for all electronics/IT equipment including printer and Projection System to be placed at lab technician table.		Anchor / Havells
3	Wiring (ISI Mark)	PVC conduits including MS/GI boxes. All wires should be covered, insulated and properly clamped. Wiring for 5 and 15A power outlets with 4 square mm PVC insulated stranded copper conductor wires Earthing of 3rd pin with PVC insulated green color 2.5 square mm copper wire	Full Lab	Supply- 2.5 mm. Running Earth- 1.5 mm (Kalinga Wires) Ups backup problem

For: SYAG Electricals &amp; Construction

With regards  
Pradosh Kumar Das  
Name & Signature with seal

PROPRIETOR