



M/S. JAYASHREE ENTERPRISES

Govt. Elect. Contractor (HT) 30 KV
Licence No. - 1871

LC-122/12, Sāilashree Vihar, Bhubaneswar. Mob. : 9437632189, 9938882553



Ref. No. JE/224/14

Date: 18-07-2014

To:

The Managing Director
Odisha Housing Corporation Ltd.
Bhubaneswar.

Subject: Verification report of ICT Lab

Dear Sir,

We are a registered contractor **Kamala Lakshmi Jena** (An approved Electrical Contractor of Government of Odisha bearing Licence No. 1871HT) for your kind perusal.

After verification of the following items of the ICT Lab at **KUSASHAKRA HIGH SCHOOL, 21170200606 PANKATA, BALIANTA, KHURDA** as per the technical specification mentioned below, the report is being sent to you being attached.

Sr. No.	Item name	Minimum Specifications	Quantity	REMARKS
1	Earthing (as per IS specifications)	Copper plate earthing system making earthing with copper earth plate 600 mm x 600 mm x 3 mm thick including solvent, characteristics, salt, oil earth work.	1	OK
2	Switches and sockets (10 Marks)	5 A-250 V switches	10	OK
		2 x 1.5A and 15A Sockets	10	OK
		15A-240V socket with shutter	2	OK
		Insulating bands - Anchor / Nails / Washers / Washers / Meters / Poles / Legand / Pils (as per) Switches and sockets to be provided for all electronic/IT equipment including printer and Projector System to be placed as per technical data		OK
3	Wiring (10 Marks)	PVC conduits including MS/GI boxes. All wires should be covered, insulated and properly clamped. Wiring for 5 and 15A power outlets with 4 square mm PVC insulated flexible copper conductor wire. Earthing of 50 sq.m with PVC insulated (steel colour) 2.5 square mm copper wire	Full Lab	400mm 50mm VSD

With regards,

Enc:

1. Verification report for the given items
2. Electrical contractor's license copy

For Registered Enterprises

Kamala Lakshmi Jena
Proprietor