



M/S. JAYASHREE ENTERPRISES

Govt. Elect. Contractor (HT) 33 KV
Licence No. - 1871

LC-122/72, Sakashree Vihar, Bhubaneswar, Mch - 9437632199, 9938860253



Ref. No. JE/2014/M

Date 16.07.2014

To

The Managing Director,
Odisha Knowledge Corporation Ltd.,
Bhubaneswar

Subject: Verification report of ICT Lab

Dear Sir,

We are a registered contractor **Kusala Laxmi Jena**, an approved Electrical contractor of Government of Odisha, bearing Licence No. 1871(NH) for your kind annual.

After verification of the following items of the ICT Lab at **S.D. HIGH SCHOOL**
21170506005 JATM/ KHURDA as per the minimum specification mentioned below, the report for the same is being attached.

Sl. No.	Item name	Minimum Specifications	Quantity	REMARKS
1	Cabling (as per IO specifications)	Copper plate earthing stations making earthing with copper earth plate. 002 nos x 800 nos x 3 nos thick including formal intermediate, salt, at each work	1	EXISTING NOT AVAILABLE
2	Switches and sockets (03 Mark)	5 A - 240 V switches	15	OK
		2 or 1 6A and 15A Sockets	15	OK
		15 A - 240 V socket with 4/15A	2	OK
		Inductive Drains - Arise / Ropets / machine / Wipro / Philips / Legrand / etc. etc.		OK
3	Wiring (03 Mark)	PVC conduits including MS/ISI boxes. All wires should be covered, insulated and properly stamped. Wiring for 5 and 15A power outlets with 4 square mm PVC insulated stranded copper conductor wires. Earthing of 3rd pin with PVC insulated green colour 2.5 square mm copper wire	Full Lab	Work done USET

With regards

Yours

1. Verification report for the given items
2. Electrical contractor's license copy

For Jayashree Enterprises