M/S. JAYASHREE ENTERPRISES

Govt. Elect. Contractor (HT) 33 KV
Licence No. - 1871
LC-122/12, Sailashree Vihar, Bhubaneswar. Mob : 9437032199, 9938866253

Ref. No. 38/2019

Date : 16.07.2019

To

The Managing Director
Odisha Knowledge Corporation Ltd.,
Bhubaneswar

Subject: Verification report of ICT Lab

Dear Sir,

We are a registered contractor **Kanaka Lochan Jena**, an approved Electrical contractor of Government of Odisha, bearing Licence No. **1871(HT)** for your kind perusal.

After verification of the following items of the ICT lab at **S.T.U.ACADEMY, KANTALBA/ 21171006705 KHURDA** as per the minimum specification mentioned below, the report for the same is being attached.

Sr. No.	Item name	Minimum Specifications	Quantity	REMARKS
1	Earthing (as per IS specifications)	Copper plate earthing stations making earthing with copper earth plate 600 mm x 600 mm x 3 mm thick including funnel, charcoal/coke, salt, all earth work	1	EARTHING NOT AVAILABLE
2	Switches and sockets (ISI Mark)	6 A- 240 V switches	15	OK
		2 in 1 6A and 16A Sockets	15	OK
		15 A - 240 V socket with shutter	2	OK
		Indicative Brands: - Anchor / Havells / Crabtree /Wipro /Philips / Legrand / Ms. Igel Switches and sockets is to be provided for all electronics/IT equipment including printer and Projection System is to be placed at lab technician table.		OK
3	Wiring (ISI Mark)	PVC conduits including MS/GI boxes. All wires should be covered, insulated and properly clamped. Wiring for 5 and 15A power outlets with 4 square mm PVC insulated stranded copper conductor wires. Earthing of 3rd pin with PVC insulated green colour 2.5 square mm copper wire	Full Lab	WORKING SAY USE

With regards

Enc:
1. Verification report for the given items
2. Electrical contractor's license copy

For Jayashree Enterprises

T/N : 21341121277, PAN : AUPJ8253Q-PF-OR-13727 ESI, OR/REV/44-6462-101-7608