



M/S. JAYASHREE ENTERPRISES

Govt. Elect. Contractor (HT) 33 KV

Licence No. - 1871

LC-122/12, Sailashree Vihar, Bhubaneswar, Mob: 9437632189, 9938866253



Ref. No. JE/179/14

Date: 14.07.2014

To
The Managing Director,
Odisha Knowledge Corporation Ltd.,
Bhubaneswar

Subject: Verification report of ICT Lab

Dear Sir,

We are a registered contractor **Kamala Lochan Jena**, an approved Electrical contractor of Government of Odisha, bearing Licence No. 1871(HT) for your kind perusal.

After verification of the following items of the ICT lab at **MUNICIPALITY CORPORATION GOVT. H.S. 21171201551 SAMANUNDA, KHURDA** as per the minimum specifications mentioned below, the report of the same is being attached.

Sr. No.	Item name	Minimum Specifications	Quantity	REMARKS
1	Earthing (as per IS specifications)	Copper plate earthing stations making earthing with copper earth plate 800 mm x 800 mm x 3 mm thick including funnel, chemical block, salt, oil earth work	1	Not satisfied
2	Switches and sockets (ISI Mark)	5 A- 240 V switches	10	OK
		2 in 1 5A and 15A Sockets	10	OK
		15 A - 240 V socket with shutter	2	OK
		indicative Brands - Anchor / Havells / castles/Wipro / Philips / Legrand (Ifs. list) Switches and sockets to be provided for all microcomput equipment including printer and Projection System to be placed at lab technician table.		OK
3	Wiring (ISI Mark)	PVC conduits including MS/GI boxes. All wires should be covered, insulated and properly stamped. Wiring for 5 and 15A power outlets with 4 square mm PVC insulated stranded copper conductor wires Earthing of 3rd pin with PVC insulated green colour 2.5 square mm copper wire	Full Lab	OK

Enc:

1. Verification report for the given items
2. Electrical contractor's licence copy

We respect your valuable EXPERIENCE

Chhaya
For/With