



M/S. JAYASHREE ENTERPRISES

Govt. Elect. Contractor (HT) 33 KV
Licence No. - 1871

LC-122/72, Srilakshmi Vihar, Bhubaneswar, Mch - 9437632199, 9938860253



Ref. No. JE/2014/M

Date 16.07.2014

To

The Managing Director,
Odisha Knowledge Corporation Ltd.,
Bhubaneswar

Subject: Verification report of ICT Lab

Dear Sir,

We are a registered contractor **Kusala Lakshmi Jena**, an approved Electrical contractor of Government of Odisha, bearing Licence No. 1871(NH) for your kind annual.

After verification of the following items of the ICT lab of **MUNICIPAL HS, KAPILAPRASAD 2227250450NH BIC, KHURDA** as per the minimum specifications mentioned below, the report for the same is being attached.

Sr. No.	Item name	Minimum Specifications	Quantity	REMARKS
1	Cabling (as per IO specifications)	Copper plate earthing stations making earthing with copper earth plate. 002 nos x 800 nos x 5 nos thick including formal insensitization, salt, at each work	1	EXISTING NOT AVAILABLE
2	Switches and sockets (0.5 Mk)	5 A - 240 V switches	15	OK
		2 or 1 5A and 15A Sockets	15	OK
		15 A - 240 V socket with 4/15A	2	OK
		Inductive Drains - Arises / Reports / routine. Wipro / Philips / Legrand / Philips. Switches and sockets to be provided for all electronics/IT equipment including printer and Projection System to be placed at lab between table.		OK
3	Wiring (0.5 Mark)	PVC conduits including MS/DI boxes. All wires should be covered, insulated and properly stamped. Wiring for 5 and 15A power outlets with 4 square mm PVC insulated stranded copper conductor wires. Earthing of 3rd pin with PVC insulated green colour 2.5 square mm copper wire	Full Lab	WORKING USE

With regards

Yours

1. Verification report for the given items
2. Electrical contractor's license copy

For Jayashree Enterprises

(Signature)