

Sandeep Mahapatra

Electrical Contractor

E.C.L. No. - 901 (M.V.)

B.O. : Power House Colony
Jeypore, (Dt. Koraput)

Mob. : 9437677771

Ph. (O): 06854 - 232660, 231967

H.O. : Susila Apartment

Near Kalinga Stadium

M-014, BBSR - 2

Mob. : 9337337773

Date 26/12/16

Ref no:

To

The Managing Director

Odisha Knowledge Corporation Ltd.,

Bhubaneswar.

Subject: Verification report of ICT lab

Dear Sir,

We are a registered contractor Mr. Sandeep Mahapatra an approved Electrical contractor of Government of Odisha, bearing Licence No. 901 (M.V.)(Copy of license is enclosed) for your kind perusal. After verification of the following items of the ICT lab at GOVT.U.G. HIGH SCHOOL,BAKODA Block: UMERKOTE, District: NABARANGPUR as per the minimum specification mentioned below, the report for the same is being attached.

Sr. No.	Item name	Minimum Specifications	Quantity
	Earthing (as per IS specifications)	Copper plate earthing stations making earthing with copper earth plate	1
		600 mm x 600 mm x 3 mm thick including funnel, charcoal/coke, salt, all earth work.	
2	Switches and sockets (ISI Mark)	5 A- 240 V switches	15
		2 in 1 5A and 15A Sockets	15
		15 A – 240 V socket with shutter	2
		Indicative Brands: - Anchor / Havells / crabtree /Wipro /Phillips / Légrand (Pls. tick) Switches and sockets is to be provided for all electronics/IT equipment including printer and Projection System to be placed at lab technician table.	✓
3	Wiring (ISI Mark)	PVC conduits including MS/GI boxes. All wires should be covered, insulated and properly clamped. Wiring for 5 and 15A power outlets with 4 square mm PVC insulated stranded copper conductor wires Earthing of 3rd pin with PVC insulated green color 2.5 square mm copper wire	Full Lab

Encl.

1. Verification report for the given items
2. Electrical contractor's licence copy

Sandeep Mahapatra
Electrical Contractor
-Cum-
Supervisor
Sandeep Mahapatra
Name & Signature with seal