

To

The Managing Director,
Odisha Knowledge Corporation Ltd.,
Bhubaneswar.

Subject: Verification report of ICT lab

Dear Sir,

We are a registered contractor RAMESH PALAI an approved Electrician workman of Government of Odisha, bearing Licence No. BBS\NGH\827 (Copy of license is enclosed) for your kind perusal.

After verification of the following items of the ICT lab at NILAKANTHESWAR HIGH SCHOOL, Saranakul, 21160718005, Odagaon, Nayagarh. as per the minimum specification mentioned below, the report for the same is being attached.

Sr. No.	Item name	Minimum Specifications	Quantity	Remarks
1	Earthing (as per IS specifications)	Copper plate earthing stations making earthing with copper earth plate	1	5 Ω
		600 mm x 600 mm x 3 mm thick including funnel, charcoal/coke, salt, all earth work.		Not ok
2	Switches and sockets (ISI Mark)	5 A- 240 V switches	15	14
		2 in 1 5A and 15A Sockets	15	18
		15 A – 240 V socket with shutter	2	1
		Indicative Brands: - Anchor / Havells / crabtree /Wipro /Phillips / Legrand (Pls. tick) Switches and sockets is to be provided for all electronics/IT equipment including printer and Projection System to be placed at lab technician table.		Anchor, All ok
3	Wiring (ISI Mark)	PVC conduits including MS/GI boxes. All wires should be covered, insulated and properly clamped. Wiring for 5 and 15A power outlets with 4 square mm PVC insulated stranded copper conductor wires Earthing of 3rd pin with PVC insulated green color 2.5 square mm copper wire	Full Lab	Wiring for 5 and 15A power outlets with 2.5 square mm PVC insulated stranded copper conductor wires Earthing of 3rd pin with PVC insulated KALINGA Green color 2.5 square mm copper wire

With regards

Name & Signature with seal

Encl.

1. Verification report for the given items
2. Electrical contractor's licence copy

Ramesh Palai

Ramesh Chandra Palai
Electrician Workman Odagaon
Li. No - BBS/NGR/827/

Pratap Kumar Mahanty

FORM - F
(Regulation 21)

ELECTRICAL WORKMAN'S PERMIT

This permit is to renewed for a period of five years at a time and must be produced on demand by the Electrical Inspector.

(Not transferable or renewable by any authority other than the Electrical Licensing Board, Orissa)

Name and Address of the holder Ramesh Palari
Date of issue of permit 26.6.2009
Category of permit W-C Workman-C (Lineman) (O.H. & U.G.)...installations including equipments upto 650 Volts
Date of approval by the E.L.B.O. Appeared in Polsh Center
Registration No. 11674-827 in the examination held on 26/6/09
127 approved in the meeting of E.L.B.O. held on 19/6/09
Date of Birth 21.06.1968
(21st June 1968)

S. Prakash
Electrical Inspector to 26/6/09
Electrical Inspector (T.O.)
Bhubaneswar